



NORTHEAST TEXAS MUNICIPAL WATER DISTRICT

REQUEST FOR PROPOSALS (RFP)

TANNER WATER TREATMENT PLANT RAW WATER PUMP INSTALLATION

Issue Date: March 6, 2026

RFP Number: CIP-TP-PUMP-2026

Proposal Due Date:

Tuesday, March 24, 2026 – 10:00 AM (Central Time)

Project Location:

Raw Water Intake – Lake O’ the Pines

Tanner Water Treatment Plant

Northeast Texas Municipal Water District (NETMWD)

1. GENERAL INFORMATION

The Northeast Texas Municipal Water District (NETMWD) is soliciting sealed proposals (bids) from qualified contractors to furnish labor, equipment, materials, transportation, installation, and supervision necessary to provide and install a new vertical turbine raw water pump at the District’s raw water intake serving the Tanner Water Treatment Plant located on Lake O’ the Pines in Marion County, Texas.

The proposer shall submit a single lump-sum price for all work described in this Request for Proposals (RFP). Prices submitted shall be final and not subject to escalation unless approved in writing by NETMWD through a formal change order.

NETMWD reserves the right to waive informalities, reject any or all proposals, and award the proposal deemed to be in the best interest of the District.

2. PROPOSAL SUBMISSION REQUIREMENTS

Proposals must be submitted in sealed envelopes and received by NETMWD no later than:

Tuesday, March 24, 2026 – 10:00 AM (CT)

Proposals may be delivered by mail, commercial carrier, or delivered in person.

Delivery Addresses

USPS:

**NETMWD
PO Box 955
Hughes Springs, TX 75656**

UPS / FedEx / In-Person Delivery:

**NETMWD
4180 FM 250 South
Hughes Springs, TX 75656**

Envelope Labeling (Required)

**RFP CIP-TP-PUMP-2026
Tanner Plant – Raw Water Pump Installation
Due March 24, 2026 at 10:00 AM**

Late proposals will not be accepted and will be returned unopened.

3. QUESTIONS AND POINT OF CONTACT

All questions regarding this RFP shall be directed to:

**Dominik Sobieraj
Assistant General Manager / Chief Operating Officer
Northeast Texas Municipal Water District**

Phone: 903-353-2510

Email: dsobieraj@netmwd.org

4. PURPOSE AND INTENT

The purpose of this project is to install an additional vertical turbine raw water pump at the NETMWD raw water intake structure serving the Tanner Water Treatment Plant.

An existing pump location is already available within the intake structure, and the project does not require removal of existing equipment.

The new pump will increase pumping capacity and operational redundancy for the Tanner Water Treatment Plant raw water supply system.

5. SCOPE OF WORK (MINIMUM REQUIREMENTS)

The successful proposer shall furnish all labor, equipment, materials, supervision, and services required to deliver a complete and operational pump installation. The minimum scope includes, but is not limited to, the following:

A. Pump Supply

1. Furnish one (1) new vertical turbine pump meeting the specifications described in this RFP.

B. Pump Installation

2. Transport the pump to the NETMWD raw water intake facility.
3. Install the pump in the existing available pump position within the intake structure.
4. Mount the pump assembly to the existing base plate.
5. Connect the pump to the existing motor and verify proper alignment.

C. Startup and Verification

6. Verify mechanical integrity and alignment of the pump assembly.
7. Coordinate installation with NETMWD operations staff.

NETMWD will provide a crane for lifting and placement of the pump assembly.

6. PUMP REQUIREMENTS

Parameter	Requirement
Pump Type	Vertical Turbine
Flow Rate	2,800 GPM
Total Dynamic Head	197 feet TDH
Stages	3 Stage
Total Pump Length	57.5 feet
Column Pipe	12-inch threaded pipe

7. EXISTING MOTOR

The new pump must be compatible with the existing motor currently installed at the intake facility.

Specification Value

Manufacturer General Electric

Horsepower 200 HP

Speed 1,200 RPM

Voltage 480 Volt

Phase 3 Phase

Motor Type Inverter Duty

Motor replacement is not included in this project.

8. PROPOSAL CONTENTS

Proposals shall include the following:

- Company qualifications and relevant experience**
- Confirmation of scope and assumptions**
- Lump-sum price for pump supply and installation**

- Estimated delivery timeline
 - Warranty information for the pump
-

9. AWARD OF PROPOSAL

Award of the proposal will be made by the NETMWD Board of Directors at a public meeting. NETMWD reserves the right to reject any or all proposals and to waive informalities.

10. AFFIDAVIT

I, _____, being an authorized representative of _____, certify that I have read, understand, and agree to the terms and conditions of this Request for Proposals.

Signature: _____

Date: _____